



PowerTags are electrical quantity measuring modules for 1P, 1P+N, 2P, 3P and 3P+N networks. They are mounted directly on equipment of the Acti 9 or Multi 9 range at intervals of 18 mm up to 63 A.

"Single terminal" devices at modules of 18 mm, rating ≤ 63A

Circuit breakers

iC60	<input checked="" type="checkbox"/>
iC65	<input checked="" type="checkbox"/>
Reflex iC60	<input checked="" type="checkbox"/>
iK60	<input checked="" type="checkbox"/>
i65N-K	<input checked="" type="checkbox"/>
DT40/i/DPN/C40	<input checked="" type="checkbox"/>
DT60	<input checked="" type="checkbox"/>
C32	<input checked="" type="checkbox"/>
C45	<input checked="" type="checkbox"/>
C60	<input checked="" type="checkbox"/>
C65	<input checked="" type="checkbox"/>
K60	<input checked="" type="checkbox"/>
C120	<input checked="" type="checkbox"/>

Residual current devices

iC60 RCBO	<input checked="" type="checkbox"/>
iKQE RCBO	<input checked="" type="checkbox"/>
C60H RCBO	<input checked="" type="checkbox"/>
iC60 Vigi	<input checked="" type="checkbox"/>
ISW 20/32 A	<input checked="" type="checkbox"/>
iID	<input checked="" type="checkbox"/>
iID K	<input checked="" type="checkbox"/>
RCCB-ID type B	<input checked="" type="checkbox"/> ≤ 63 A
IDc/ITG40/C40	<input checked="" type="checkbox"/>
DCP Vigi	<input checked="" type="checkbox"/>
DPN Vigi K	<input checked="" type="checkbox"/>
RED	<input checked="" type="checkbox"/>
RCCB	<input checked="" type="checkbox"/>

Switches

iSW ≥ 40 A	<input checked="" type="checkbox"/>
iSW-NA	<input checked="" type="checkbox"/>
I-NA	<input checked="" type="checkbox"/>

"Single terminal" devices at modules of 18 mm, rating ≤ 63A		
Resi 9 Belgium	Upstream	Downstream
Circuit breaker	☑	☒
RCCB	☑	☒
RCBO	☒	☒
Switches	☑	☒
Resi 9 International		
Circuit breaker	☒	☑
RCCB	☒	☑
RCBO	☒	☒
Switches	☒	☑
iKQ		
iKQ circuit breaker	☒	☑
iKQE RCBO	☒	☒



1.0	22/03/2016	Creation	Sonovision
Indice	Date	Modification	Name